Changeover switch, RMQ-Titan, With thumb-grip, momentary, 2 positions, Bezel: titanium ${\bf RMQ}$



Part no. M22-WK 216865

EL Number

4355316

(N	orway
----	-------

General specifications	
Product name	Eaton Moeller® series M22 Changeover switch
Part no.	M22-WK
EAN	4015082168650
Product Length/Depth	46 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.013 kilogram
Compliances	CE Marked
Certifications	UL 508 CSA Std. C22.2 No. 14-05 EN 60947-5 IEC 60947-5 CSA Std. C22.2 No. 94-91 VDE CSA File No.: 012528 CSA-C22.2 No. 14-05 CE IEC/EN 60947 UL CSA UL Category Control No.: NKCR IEC/EN 60947-5 CSA Class No.: 3211-03 CSA-C22.2 No. 94-91 VDE 0660 UL File No.: E29184
Product Tradename	M22
Product Type	Changeover switch
Product Sub Type	None
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	With thumb-grip
Fitted with:	Front ring
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
General information	
Accessories	Thumb grip
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	2000 Operations/h
Operating torque	0.3 N⋅m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Switching angle	40 °
Туре	Selector switch actuator
Ambient conditions, mechanical	
Mounting position	As required
Shock resistance	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms
Climatic environmental conditions	
Ambient operating temperature - min	-25 °C

Anberd storage temperature - mix Anberd storage temperature - mix Anberd storage temperature - mix Dissistic preafing Disministration Communication Communication Conscious to SmartWire-DT Vec Communication Conscious to SmartWire-DT Vec Conscious to SmartWire-DT Vec Actuator Actuator Vec Conscious System-steam Actuator Vec Actua		
Ambient storage temperature - max Climate profering Damp beat, cyclic, to IEC 80982-2-78 We Which SVID 84MQ connections Actuator Actuator Actuator Actuator (Actuator Intention Actuat	Ambient operating temperature - max	70 °C
Climatic proofing Damp heat. constant, to IEC 20009-2-78 Damp heat. cyclic, to IEC 20009-2-78 Damp heat. cyclic, to IEC 20009-2-78 Damp heat. cyclic, to IEC 20009-2-79 Damp heat. cyclic, to IEC 20009-2-79 Damp heat. cyclic, to IEC 20009-2-79 Was With SVD-RIMQ connections Actuator Actuator Date of the Actuator of the Actuator color Actuator type Actuator type Date of the Actuator type Actuator type Number of switch positions 2 Contacted Force for positive opening - min Dosign verification Equipment heat dissipation, current-dependent Pvid OV Heat dissipation, current-dependent Pvid OV Read operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read of operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read of operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read of operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read of operational current for specified heat dissipation (In) Static heat dissipation, num-current-dependent Pvid OV Read of operations of standard is requirements. Meets the product standard is requirements. 10.2.2 Corresions of resistance of insulation, materials doct, effects Over not apply, since the entire switchpear needs to be evaluated. Meets the product standard is requirements. Meets the product standard is requirements. 10.2.8 Mechanical impact Over not apply, since the entire switchpear needs to be evaluated. Meets the product standard is requirements. 10.2.9 Divers of production of searching and connections In Divers of the operation of searching and connections In Divers of the operation of searching and connections In Divers of the operation of searching and connections In Divers of the operation of searching and connections In	Ambient storage temperature - min	-40 °C
Communication Connection to SmartWire-DT Yes With SWD-RMD cannections Actuator color Actuator rector Actuator rector Actuator rype Actuator rype Actuator rype Number of avoich positions Contacts Force for positive opening - min Osign everification Equipment heat dissipation, current-dependent Pvid Heat dissipation gazery Pdiss OW Heat dissipation on a project, current-dependent Pvid OW Retado porational current for specified heat dissipation (in) Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) OA Static heat dissipation, one-current-dependent Pvid OW Retado porational current for septime heat dissipation (in) OA Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) OA Static heat dissipation, one-current-dependent Pvid OW Retado porational current for specified heat dissipation (in) OB Static heat dissipation, one-current-dependent Pvid OW Retado for specific the form of static specified heat dissipation (in) OB Composition of thermal stability of anciosures Meets the product standard's requirements. Decay one capity, since the entire svoict-pager needs to be evaluated. Do Septime of product canned or sequirements. Decay on capity, since the entire svoict-pager needs to be evaluated. Do Septime of product canned or sequirements. Decay on capity, since the entire svoict-pager needs to be evaluated. Do Septiment of various entires sponsibility. In the panel builder's responsibility. In the panel builder's responsi	Ambient storage temperature - max	2° 08
Connection to SmartWire-DT Actuator Actuator color Actuator function Actuator function Actuator function Actuator function Actuator sype Toggle Number of switch positions Contacts Force for positive opening - min Design verification Epipinent heat dissipation, current dependent Pvid DW Heat dissipation capacity Pdiss DW Heat dissipation actuatory specification Epipinene heat dissipation, current dependent Pvid DW Heat dissipation per pole, current dependent Pvid DW Heat dissipation per pole, current dependent Pvid DW Heat dissipation per pole, current dependent Pvid DW Heat dissipation in the specification of the strain shall yet acclosures District in the specification of the strain shall yet acclosures Meets the product standard's requirements. 10.2.2 Grossion resistance Meets the product standard's requirements. 10.2.3 Notice in or resistance of insulating materials to normal heat 10.2.3 Section floating and the shall will be shall be	Climatic proofing	
Actuator color Actuator function Actuator type Actuator type Actuator type Number of swirch positions Contacts Force for positive epaming - min Design verification Equipment heart dissipation, current-dependent Pvid Heat dissipation current dispendent Pvid Heat dissipation current dispendent Pvid Heat dissipation current-dependent Pvid Heat dissipation current-dependent Pvid Related operational current for spocified heat dissipation (In) Related operational current dispendent Pvid Related operational current for spocified heat dissipation (In) Related operation of severation of spocified heat dissipation (In) Related operation of severation of spocified heat dissipation (In) Related operation of severation of severation of sinulation materials to normal heat Related operation of severation of	Communication	
Actuator color Actuator function Dosign verification Equipment heat dissipation current-dependent Pvid OW Heat dissipation capacity Pdits OW Retade dissipation current for specified heat dissipation (In) Actuator function of the function of th	Connection to SmartWire-DT	
Actuator function Spring-return Momentary Actuator type Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid OW Heat dissipation per pole, current-dependent Pvid OW Static heat dissipation non-current for specified heat dissipation (In) Static heat dissipation non-current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis OW Meets the product standard's requirements. 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of esistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to sultra-violet (IV) radiation 10.2.5 Lirting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.6 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Protection of switching devices and coneponents 10.7 Internal electrical circuits and connections 10.8 Connections for external conquirements. 10.9 Protection of switching devices and connections 10.9 Protection of switching d	Actuator	
Actuator type Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation, non-current dependent Pvid Heat dissipation, non-current d	Actuator color	Black
Actustor type Number of switch positions Contacts Force for positive opening - min Do N Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation, per pole, current-dependent Pvid Attacts dissipation, non-current-dependent Pvid Bate operational current for specified heat dissipation (in) 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.2.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating material 10.2.3.2 Verification of resistance of insulating material 10.2.3.3 Verification of resistance of insulating material 10.2.3.4 Design of resistance of insulating material 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entrice switchgear needs to be evaluated. 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.8 Does not apply, since the entrice switchgear needs to be evaluated. 10.9 Does not apply, since the entrice switchgear needs to be evaluated. 10.9 Does not apply, since the entrice switchgear needs to be evaluated. 10.1 Teternal electrical circuits and connections 10.3 Degree of protection of switching devices and components 10.5 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strongth 10.9.4 Tetrainal electrical circuits and connections 10.9.5 Internal electrical circuits and connections 10.9.5 Internal electrical circuits and connections 10.9.5 Internal electrical circuits and connections 10.9.1 Tetranal electrical circuits and connections 10.9.1 Tetranal electrical circuits and connections 10.9.2 Internal electrical circuits and connections 10.9.3 Internal electrical circuits and connections 10.9.4 Tetranal electrical circuits and connection	Actuator function	
Contacts Force for positive opening - min Design verification Equipment hard dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Reted operational current for specified heat dissipation (In) Reted dissipation, non-current-dependent Pvis Reted dissipation, non-current-dependent Reted		
Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UVI) radiation 10.2.5 Litting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3.0 legree of protection of assemblies 10.3.0 legree of protection of assemblies 10.4 Decrances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of switching devices and components 10.9 Internal electric shock 10.9 Internal electric shock 10.9 Internal placetric strength 10.9 I		
Porce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation [n] Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation [n] OA Static heat dissipation, non-current-dependent Pvs OW 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Litting Obes not apply, since the entire switchgear needs to be evaluated. 10.2.7 Incrpitions Meets the product standard's requirements. 10.2.8 Mechanical impact 10.2.9 Litting Obes not apply, since the entire switchgear needs to be evaluated. 10.2.1 Incrpitions Meets the product standard's requirements. 10.3.0 Legree of protection of assemblies Obes not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Incorporation of assemblies Obes not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Obes not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components In the panel builder's responsibility. 10.8 Connections for external conductors 10.9 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Number of switch positions	2
Design verification	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss DW Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) OA Static heat dissipation, non-current-dependent Pvs DW 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components List the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Electromagnetic compatibility Step panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Resists of insul. mat. to abnormal heat fire by internal elect. affects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.8 Ones of tapply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 To mere are unconsulted to be evaluated. 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 To mere are unconsulted to be evaluated. 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Meets the product standard's requirements. Meets the product standard's requirements. 10.4 Meets the product standard's requirements. 10.5 Protection against electric switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Legal Device the entire switchgear needs to be evaluated. 10.9 Power-frequency electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility. 10.13 Mechanical function 10.13 Mechanical function	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Resists. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.8 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions 10.30 Begree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.30 Does not apply, since the entire switchgear needs to be evaluated. 10.40 Clearances and creepage distances 10.44 Clearances and creepage distances 10.45 Protection against electric shock 10.56 Protection against electric shock 10.57 Protection of switching devices and components 10.58 Incorporation of switching devices and components 10.59 Power-frequency electric strength 10.50 Supply, since the entire switchgear needs to be evaluated. 10.71 Internal electrical circuits and connections 10.51 Internal electrical circuits and connections 10.52 Internal electrical circuits and connections 10.53 Impulse withstand voltage 10.54 Clearances and or expensibility. 10.55 Protection agenises and connections 10.56 Incorporation of switching devices and components 10.57 Internal electrical circuits and connections 10.58 Internal electrical circuits and connections 10.59 Internal electrical circuits and connections 10.59 Internal electrical circuits and connections 10.50 Internal electrical circuits and connections 10.51 Internal electrical circuits and connections 10.52 Internal electrical circuits and connections 10.53 Internal electrical circuits and connections 10.54 Internal electrical circuits and connections 10.55 Internal electrical circuits	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not apply builder's responsibility. 10.10 Temperature rise Not apple builder's responsibility. 10.12 Electromagnetic compatibility 10.13 Mechanical function Neets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.	Rated operational current for specified heat dissipation (In)	0 A
10.2.3 I Verification of thermal stability of enclosures 10.2.3 Perification of resistance of insulating materials to normal heat 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Dewer-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. 10.12 Electromagnetic compatibility 10.13 The panel builder's responsibility. 10.14 Esting of enclosures made of insulating material 10.15 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 Mechanical function The device meets the requirements, provided the information in the instruction	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Power-frequency electric strength 10.9.3 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Electromagnetic compatibility 10.14 Electromagnetic compatibility 10.15 Internal electric strength 10.16 Internal electric strength 10.17 Internal electric strength 10.18 Internal electric strength 10.19 Internal electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Electromagnetic compatibility 10.14 Electromagnetic compatibility 10.15 Internal electric external conductors 10.16 Internal electric external conductors 10.17 Internal electric external conductors 10.18 The panel builder's responsibility. 10.19 The device meets the requirements. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Electromagnetic compatibility 10.14 Electromagnetic formation in the instruction 10.15 The device meets the requirements, provided the information in the instruction	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Impulse withstand voltage 10.9.2 Fower-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 1s the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1c.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])

[AKF031014])	
Number of switch positions	2
Type of control element	Toggle
Suitable for illumination	No
Colour control element	Black
Colour indicator light cap	Other
Construction type lens	Round

Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		No
Spring-return		Yes
With front ring		Yes
Material front ring		Plastic
Colour front ring		Titanium
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13