DATASHEET - M22-DL-G



$Illuminated\ pushbutton\ actuator,\ RMQ-Titan,\ Flush,\ momentary,\ green,\ Blank,\ Bezel:\ titanium$

Part no. M22-DL-G

216927

EL Number (Norway)

4355344

(Norway)	
General specifications	
Product name	Eaton Moeller® series M22 Illuminated pushbutton actuator
Part no.	M22-DL-G
EAN	4015082169275
Product Length/Depth	30 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.01 kilogram
Compliances	CE Marked
Certifications	DNV GL LR CSA-C22.2 No. 14-05 IEC/EN 60947 UL Category Control No.: NKCR CSA Class No.: 3211-03 CSA VDE 0660 CSA File No.: 012528 UL File No.: E29184 IEC/EN 60947-5 CSA-C22.2 No. 94-91 CE UL VDE IEC 60947-5 CSA Std. C22.2 No. 14-05 CSA Std. C22.2 No. 94-91 EN 60947-5 UL 508
Product Tradename	M22
Product Type	Illuminated pushbutton actuator
Product Sub Type	None
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	Classical Flush
Fitted with:	Front ring
Inscription	Blank
Material	Titanium front ring
General information	
Degree of protection	NEMA 4X IP69K IP66 NEMA 3R IP67 NEMA 13 NEMA 12
Degree of protection (front side)	IP67/IP69K NEMA 4X
Lifespan, mechanical	5,000,000 Operations
Opening diameter	22.5 mm
Operating frequency	3600 Operations/h
Product category	RMQ-Titan
Size	Front dimensions: 22 x 22 mm
Suitable for	Illumination
Туре	Illuminated pushbutton actuator

observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Ambient conditions, mechanical	
Shock resistance Climatic environmental conditions Antient operating temperature - min Damp heat, cyclic, to IEC 60088-2-00 Damp	Mounting position	As required
Ambient operating tamperature - min Ambient operating tamperature - max Climatic profing Communication Commercion to SmartWive-DT Ves Was SVD-HMQ connections Actuator Actuator farce Actuator color Actuator color Actuator color Actuator process of the profit of t		
Ambient operating temperature - max Climate proefing Damp heat, corstant, to IEC 60008-2-78 Damp heat department, to IEC 60008-2-78 Damp heat, corstant, to I	Climatic environmental conditions	
Climate proofing Communication Connection to SmartWire-DT Wis SWO-RMQ connections Actuator Actuator color Actuator Actuator color Actuator Actuator color Actuator Actuator color Actuator Actuator color Actuator Actua	Ambient operating temperature - min	-25 °C
Communication Communication Communication Communication Commercion to SmartWire-DT Actuator Actuating force Actuating force Actuating force Actuating force Actuating force Actuating force Actuation Actuation Actuator function Actuator function Actuator function Actuator function Actuator function Actuator function Design verification Equipment heat dissipation, current-dependent Perd Force for proprior againty - Picis Equipment heat dissipation parapole, current-dependent Perd Beard dissipation parapole, current-dependent Perd Beard dissipation parapole, current-dependent Perd But dependent current for specified heat dissipation (in) Retard dispitation actuatory for specified heat dissipation (in) But actuation actuatory for specified heat dissipation (in) But actuatory for specified heat dissipation (in) But actuation of swelt-paraments. But actuatory in specified heat dissipation (in) But actuatory in	Ambient operating temperature - max	70 °C
Contection to SmartVine-DT Actuator Actuating force Actuatin	Climatic proofing	
Actuator valuator Actuator force Actuator function Actuator British possible opening - min Actuator Design verification Besign verification Actuator Use of the product standard of the pr	Communication	
Actuator force Actuator function Actuator function Actuator function Spring-return Momentary Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid OW Heat dissipation expacity Pdiss OW Heat dissipation per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid OW 10.2.2 Corrosion resistance Meats the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meats the product standard's requirements. 102.2.3 Verification of resistance of insulating materials to normal heat Meats the product standard's requirements. 102.2.3 Resistance to ultra-violet (IUV) radiation Please enquire Des not apply, since the entire switchgear needs to be evaluated. 10.2.4 Resistance to ultra-violet (IVV) radiation Please enquire Des not apply, since the entire switchgear needs to be evaluated. 10.2.1 Inscriptions Meats the product standard's requirements. Meats the product standard's requirements. Meats the product standard's requirements. 10.2.1 Inscriptions Des not apply, since the entire switchgear needs to be evaluated. 10.2 Protection against electric shock Des not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and cropage distances Meats the product standard's requirements. 10.5 Protection against electric shock Des not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electric clicruits and connections 10.8 Interport product standard's requirements. 10.9 Perventure rise 10.1 Internal electric clicruits and connections 10.2 Power-frequency electric strangth 10.3 Internal electric clicruits and connections 10.4 Electromagnetic circuits and connections 10.5 Interpolation of switching devices and connections 10.6 Interpolation of switching devices and connections 10.7 Internal electric clicruits and connections 10.8 Interpolation of	Connection to SmartWire-DT	
Actuator color Actuator function Contacts Force for positive opening - min Design vertification Equipment heat dissipation, current-dependent Pvid Heat dissipation current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Static heat dissipation, non-curront-dependent Pvid Heat dissipation, non-curront-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-curront-dependent Pvis Rated operational current for specified heat dissipation (In) Static heat dissipation, non-curront-dependent Pvis Rated operational current for specified heat dissipation (In) Static heat dissipation, non-curront-dependent Pvis Rated operational current for specified heat dissipation (In) Static heat dissipation, non-curront-dependent Pvis Rated dissipation, non-curront-dependent Pvis Read dissipation, non-curront-dependent Pvis Read dissipation, non-current-dependent Pvis Read dissipation, non-current-dependen	Actuator	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pfiss Heat dissipation per pole, current-dependent Pvid Attended operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid OW Static heat dissipation, non-current-dependent Pvid 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification or resistance Meets the product standard's requirements. 10.2.3.2 Resistance of insulating materials to normal heat 10.2.3.2 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creapage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Incorporation of switching devices and components 10.5 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 In Industrial vertices and connections 10.1 Internal electrical circuits and connections 10.2 Internal electrical circuits and connections 10.3 Impulse withstand voltage 10.4 It send polluder's responsibilit	Actuating force	5 N
Contacts Force for positive opening - min Design verification Equipment had dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) O A Static heat dissipation, non-current-dependent Pvis 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (IU) radiation 10.2.5 Urting Does not apply, since the entire switchpear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Mechanical impact Does not apply, since the entire switchpear needs to be evaluated. 10.4 Clearances and croepseg distances Meets the product standard's requirements. 10.9 Protection against electric shock Does not apply, since the entire switchpear needs to be evaluated. 10.4 Clearances and croepseg distances Meets the product standard's requirements. Does not apply, since the entire switchpear needs to be evaluated. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchpear needs to be evaluated. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchpear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 2 Power-frequency electric strength 10.9 3 Impulse withstand voltage 10.9 4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Level Served. 10.12 Electromapnetic competibility 10.13 Mechanical function Th	Actuator color	Green
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation on-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Commections for external conductors 10.9 The panel builder's responsibility. 10.9 The panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 11.15 Internal electric shock 10.15 The panel builder's responsibility. 11.16 The panel builder's responsibility. 11.17 The panel builder's responsibility. 11.18 The panel builder's responsibility. 11.19 The panel builder's responsibility. 11.19 The panel builder's responsibi	Actuator function	Spring-return
Posign verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation proble, current-dependent Pvid OW Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23 I Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect effects 10.24.2 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27.1 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Fower-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Timpulse withstand voltage 11.1 Short-circuit rating 10.9 Timperature rise Not applicable. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.13 Mechanical function The device meets the requirements, provided the information in the instruction observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction observed.	Contacts	Momentary
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Do A Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Not Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear meets observed. 10.13 Mechanical function The device meets the requirements, provided the information in the ins		0.01
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid And operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW OU 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Incriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Temperature rise Not applicable. 10.1 Temperature rise Not applicable. 10.1 Short-circuit rating Does not apply, since the untire switchgear meeds to be evaluated. 10.1 Temperature rise Not applicable. 10.1 Electromagnetic compatibility 10.1 Short-circuit rating Does not apply since the entire switchgear meeds to be evaluated. 10.1 The device meets the requirements, provided the information in the instruction observed.		UN
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) OA Static heat dissipation, non-current-dependent Pvis OW 10.22 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 102.4 Resistance to ultra-violet (UV) radiation 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.8 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 104.4 Clearances and creepage distances Meets the product standard's requirements. 105.5 Protection against electric shock 106.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 107.7 Internal electrical circuits and connections In the panel builder's responsibility. 108.2 Connections for external conductors Is the panel builder's responsibility. 109.2 Power-frequency electric strength Is the panel builder's responsibility. 109.4 Testing of enclosures made of insulating material 10.10 Temperature rise In the panel builder's responsibility. 109.4 Testing of enclosures made of insulating material 10.11 Short-circuit rating In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear medserved. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear medserved. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction.	· ·	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0W Mets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance or insulating materials to normal heat 10.2.3.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assamblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.14 Electromagnetic compatibility 10.15 Internal electrications 10.15 Internal electrications 10.16 Internal electric strength 10.17 Electromagnetic compatibility 10.18 the panel builder's responsibility. 10.19 Power-frequency electric strength 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction The device meets the requirements, provided the information in the instruction		
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. Is the panel builder's responsibility. The specifications for the switchgear medoserved. 10.11 Short-circuit rating Lis the panel builder's responsibility. The specifications for the switchgear medoserved. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction and the information in the in		
Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear mobserved. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Internal electrical circuits and connections 10.18 Lepanel builder's responsibility. 10.29 Power-frequency electric strength 10.30 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.29 Power-frequency electric strength 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.20 Meets the product standard's requirements. 10.21 Meets the product standard's requirements. 10.22 Meets	Rated operational current for specified heat dissipation (In)	
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction the force of the switchgear measure observed.	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. In the device meets the requirements, provided the information in the instruction of the switchgear multiple observed.	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3. Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. The specifications for the switchgear multiposerved. In the device meets the requirements, provided the information in the instruction the device meets the requirements, provided the information in the instruction.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Gere of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Please enquire Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility in the specifications for the switchgear material builder's responsibility. In the panel builder's responsibility.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear many observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear multiposerved. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1 Is the panel builder's responsibility. 10.8 Connections for external conductors 1 Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1 Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1 Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 1 Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function 1 The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Internal electrical circuits and connections Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Steppens builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 Mechanical function 10.16 Temperature rise observed. 10.17 The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed. 1s the panel builder's responsibility. The specifications for the switchgear multiple observed.	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.16 The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Sthe panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.15 the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.16 the panel builder's responsibility. The specifications for the switchgear multiple observed.	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Not applicable. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. Is the panel builder's responsibility. The specifications for the switchgear multiple observed. The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear multiple observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must b observed.
	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must b observed.
leafiet (IL) is observed.	10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for push button (EC000221)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for push-button actuators (ecl@ss13-27-37-12-10 [AKF028019])

E ====	
Colour button	Green
Number of command positions	1
Construction type lens	Round

Hole diameter	m	mm	22.5
Width opening	m	mm	0
Height opening	m	mm	0
Type of button			Flat
Suitable for illumination			Yes
With protective cover			No
Labelled			No
Switching function latching			No
Spring-return			Yes
With front ring			Yes
Material front ring			Plastic
Colour front ring			Titanium
Degree of protection (IP), front side			IP67/IP69K
Degree of protection (NEMA), front side			4X